

THE AUTOMATIC SPRINKLER INSPECTION BUREAU (PTY) LIMITED



1407 IMBALI
CNR LOUIS BOTHA AND
TUDHOPE AVENUES
BEREA
JOHANNESBURG
2198

P O BOX 3139
HOUGHTON
2041

TELEPHONE: +27 11 642 1703
FACSIMILE: +27 11 642 1019
E-MAIL: asib@asib.co.za
WEB SITE: www.asib.co.za

CLEARANCE CERTIFICATE

Full Protection

THIS IS TO CERTIFY THAT THE SPRINKLER SYSTEM INSTALLED AT

Technipaint

63 Teakwood Road, Jacobs, Durban

Was inspected during:

December 2021

Pursuant to the terms of contract number:

011738

Entered into with:

Technipaint Holdings Pty Ltd

and that the premises which are protected, complies with the Fire Protection standards currently acceptable to Insurance Companies for Full and Compartmentalised Protection in respect of sprinkler design, spacing and location. This certificate is subject to the terms of the contract described above shall remain valid for a period of six months.

Twelfth Edition

Edition sprinkler rules

Single

Water supply

Two

Units of hand fire appliances per 100m² of floor area

Hazard Percentage	(%)	Design Density of Discharge (mm/min)
Extra Light	N/A	N/A
Ordinary	5	5 mm/min
High	95	25,0 mm/min

Rack Protection **No**

Category **IV**

Shelf Protection **No**

Signed:

Date: **December 2021**